

PUBLIC NOTICE

The following matters are the subject of this public notice by the Ohio Environmental Protection Agency. The complete public notice, including any additional instructions for submitting comments, requesting information, a public hearing, or filing an appeal may be obtained at: [Weekly Review and Public Notices | Ohio Environmental Protection Agency](#) or Hearing Clerk, Ohio EPA, 50 W. Town St., Columbus, Ohio 43215. Ph: 614-644-3037 email: HClerk@epa.ohio.gov

Draft Air Pollution Permit-to-Install Initial Installation

Chestnut Run Energy LLC
2276 Mobile Rd
Carrollton, OH 44615

ID#: P0138841

Date of Action: 01/26/2026

Permit Desc: Initial installation PTI of a NG-fired combined cycle combustion turbine electric generating facility, nominally rated at 1,300 MW.

Carroll County

PUBLIC NOTICE

Issuance of Draft Air Pollution PSD Permit

Chestnut Run Energy LLC

Issue Date: January/23/2026

Permit Number: P0138841

Permit Type: PSD

Facility ID: 0210012080

Facility Location: 2276 Mobile Road

Carrollton, OH 44615

Permit/Facility Description: Permit-to-install (PTI) for installation of a nominal net 1,300 MW Potential combined-cycle gas turbine (CCGT) electric generating facility located in Carroll County.

The Director of the Ohio Environmental Protection Agency, 50 West Town Street, Columbus Ohio has issued a draft air pollution control Prevention of Significant Deterioration (PSD) installation permit for the listed facility. The draft permit is being issued to solicit comments from any interested party for the director to consider prior to making a final decision.

The proposed allowable emission rates of PSD pollutants from the facility in tons per rolling 12 month period are: Nitrogen Oxides (NOx) 341.67; PM less than or equal to 10 microns (PM10) and PM less than or equal to 2.5 microns (PM2.5) 202.08; Sulfur Dioxide (SO2) 65.04; Volatile Organic Compounds (VOC) 125.86; Carbon Monoxide (CO) 282.28; Sulfuric Acid (H2SO4) 46.46; Greenhouse Gas/Carbon Dioxide equivalent 5,235,432. Air dispersion modeling was performed to show allowed emission levels will not cause or contribute to an exceedance of any National Ambient Air Quality Standard (NAAQS) or the PSD Class II Significant Impact Levels. The maximum air pollutant concentrations and averaging periods that are expected from this facility are the following in micrograms per cubic meter: 7.10 nitrogen dioxide 1-hour, 0.47 nitrogen dioxide annual, 1.09 PM 2.5 24-hour, 0.10 PM2.5 annual, 0.10 PM10 24-hour, and 1.63 SO2 1-hour. Air dispersion modeling was also performed to evaluate potentially toxic compounds and passed all toxic modeling thresholds. All other pollutants were too small to model.

Written comments on the draft permit must be received by the close of the business day on February 23, 2026. Comments received after this date may not be considered a part of the official record. Written comments may be submitted to: Kevin Fortune, Ohio EPA DAPC, Northeast District Office, 2110 East Aurora Rd., Twinsburg, OH 44087, kfortune@epa.ohio.gov

Any person may request a public hearing and if the agency determines that significant public interest is shown, a public hearing may be held concerning the draft permit. The draft permit and complete instructions for requesting information or submitting comments may be obtained at: <https://epa.ohio.gov/help-center/edocument-search/edocument-search> by entering the permit number P0138841. Or by contacting: Kevin Fortune, Ohio EPA DAPC, Northeast District Office, 2110 East Aurora Rd., Twinsburg, OH 44087. Physical copies of the permit or copies of supporting records may be inspected and copied at the DO or LAA, located at the above address, telephone number 330-963-1200.

Persons interested in joining Ohio EPA's mailing list concerning this or similar actions may sign up using the following link:
https://public.govdelivery.com/accounts/OHEPA/subscriber/new?topic_id=OHEPA_281&pop=t